

# END OF SEASON/WINTERIZATION CHECKLIST



## FLOW THROUGH & WQMS

WATER MANAGEMENT SYSTEM	YES	NO	N/A
ENSURE THE WINTERIZATION PROCEDURE FOUND IN YOUR VORTEX OWNER OPERATOR MANUAL IS FOLLOWED FT & WQMS			
WQMS SYSTEM IS FULLY DRAINED WQMS			
PUMP STRAINER BASKETS ARE CLEAN WQMS			
Y STRAINERS ARE CLEAN - DOES YOUR STRAINER MESH NEED REPLACING? WQMS			
WATER CONTAINMENT RESERVOIR IS APPROPRIATELY EMPTIED AND CLEANED WQMS			
CHEMICAL RESERVOIRS ARE EMPTY AND CHEMICALS ARE CORRECTLY DISPOSED OF WQMS			
CHEMICAL PROBES ARE REMOVED, CLEANED AND APPROPRIATELY STORED WQMS			
SAND FILTER IS APPROPRIATELY DRAINED AND CLEANED WQMS			
MAIN WATER SUPPLY IS SHUT OFF FT & WQMS			
MANIFOLD IS FULLY DRAINED - DRAIN VALVES OPEN FT & WQMS			
MAIN ELECTRICAL SUPPLY IS TURNED OFF FT & WQMS			
DEBRIS TRAP IS CLEANED AND IN THE STORM/SANITARY POSITION WQMS			
DECK DRAINS ARE CLEAN FT & WQMS			

PLAY FEATURES	YES	NO	N/A
ENSURE ALL FEATURE LINES ARE APPROPRIATELY DRAINED FT & WQMS			
INSPECT ALL FEATURE HARDWARE AND TIGHTEN / REPLACE AS NECESSARY FT & WQMS			
REMOVE AND CLEAN ALL SPRAY NOZZLES - REPLACE ANY WITH WORN OR DAMAGED THREADS FT & WQMS			
INSTALL ALL WINTER CAPS WHERE APPLICABLE - ARE YOU MISSING ANY? FT & WQMS			
INSPECT ALL STATIC / ROTATIONAL JOINTS FOR WORN PARTS - GREASE AND REPLACE AS NECESSARY FT & WQMS			
INSPECT ALL PRODUCT ACCESSORIES (SEEFLOW, DUMPING BELLS, ETC...) FOR ANY DAMAGE - REPLACE WHERE NECESSARY FT & WQMS			
ALL FEATURES SHOULD BE THOROUGHLY CLEANED OF ANY HARD WATER DEPOSITS AND SURFACE DEFICIENCIES FT & WQMS			

ELEVATIONS STRUCTURE	YES	NO	N/A
ENSURE ALL POSTS, LINES AND ACCESSORIES ARE COMPLETELY DRAINED WQMS			
INSPECT ALL HARDWARE AND TIGHTEN OR REPLACE AS NECESSARY WQMS			
INSPECT ALL NETTING, ZIPPERS AND LOCKS - REPLACE AS NECESSARY WQMS			
INSPECT ALL SLIDES AND REPAIR AS NECESSARY WQMS			
CLEAN ENTIRE STRUCTURE REMOVING ANY HARD WATER DEPOSITS AND SURFACE DEFICIENCIES WQMS			
INSPECT ALL STATIC / ROTATIONAL JOINTS FOR WORN PARTS - GREASE AND REPLACE AS NECESSARY WQMS			
INSPECT ALL PRODUCT ACCESSORIES (SEEFLOW, DUMPING BELLS, ETC...) FOR ANY DAMAGE - REPLACE WHERE NECESSARY WQMS			
ENSURE ALL MANIFOLDS ARE DRAINED WQMS			

